

MUSE LIGHT acoustic

suspended

091-121163EF



Project / Type

Notes

Count / Date



General

Ceiling , Suspended

indigo blue

IP20

2200 lm

LED

4000 K

CRI \geq 80

L90 / 50000 h

initial MacAdam \leq 3 SDCM

MR 0.72

MDER 0.66

Optical

UGR $<$ 19 , \geq 65° $<$ 1500 cd/m²

PstLM \leq 1.0¹

SVM \leq 0.4¹

Electrical

DALI-2

20.3 W

PC1 220-240V

108 lm/W

1 DALI Addr.

Physical

length 1600 mm


width 46 mm

height 380 mm


3.9 kg

Luminaire body made of high quality, self-supporting PET felt with sound absorbing properties, consisting of 50% recycled PET; high quality visual and tactile surface, indigo blue; colour may deviate; constructed of 2 shells to form cavities that improve acoustic performance; large sound absorbing surface; suspended luminaire with 1500mm cable suspension; with integrated tool-less suspension height adjustment; spring clip attachment to the luminaire; freely positionable; incl. transparent feed; optimised for the illumination of office workstations; light inset made from extruded profile for improved thermal management; light colour 4000 K; binning initial MacAdam \leq 3 SDCM; CRI \geq 80; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; high gloss reflector with faceted design; blind covers in gray; UGR \leq 19; VDU compatible workplace luminaire according to DIN EN 12464-1; luminance above 65° \leq 1500 cd/m²; degree of protection IP20; PC1 220-240V; internal wiring in light halogen free; incl. DALI-2 converter; light source not replaceable; control gear replaceable by an authorized professional;

Light distribution



Product drawing



¹ Value of containing product at full load (undimmed)

Installation instructions



Lighting calculator



MUSE LIGHT acoustic

suspended

091-121163EF



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.95	0.93	0.91	0.9
LSF	1	1	1	1	1

MF	LMF × RSMF × LLMF × LSF	RSMF ^a	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF ^a	Luminaire Maintenance Factor	LSF	Lamp Survival Faktor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	18
B13	23
B16	28
B20	35
C10	30
C13	38
C16	46
C20	58