

# BETO circle 1600 direct / indirect power

suspended

074-7444538R



Project / Type

Notes

Count / Date



## General

Ceiling , Suspended

black , RAL9005 <sup>1</sup>

Reflector chrome

IP20

indirect 12200 lm

direct 12800 lm

total 25000 lm

## LED

3000 K

CRI ≥ 80

L90 / 50000 h

initial MacAdam ≤ 3 SDCM

MR 0.56

MDER 0.51

## Optical

Reflector

Symmetric

UGR < 13 , ≥65° <1500 cd/m<sup>2</sup>

PstLM ≤ 1.0 <sup>2</sup>

SVM ≤ 0.4 <sup>2</sup>

## Electrical

DALI-2

172 W

PC1 220-240V

145 lm/W

2 DALI Addr.

## Physical


diameter 1569 mm

height 42 mm


<sup>1</sup> RAL code <sup>2</sup> Value of containing product at full load (undimmed)

Ring-shaped light fitting in rolled and seamlessly welded extruded aluminium profile; extremely slim design (only 42 x 42 mm); suspended luminaire with 1500mm cable suspension (canopy central); with integrated tool-less suspension height adjustment; incl. transparent feed; extruded profile for improved thermal management; energy efficient LEDs with high CRI; high gloss reflector with faceted design; internal wiring in light halogen free; incl. converter, non dimmable; converter included in canopy;

## Light distribution



## Product drawing



## Installation instructions



## Lighting calculator



# BETO circle 1600 direct / indirect power

suspended

074-7444538R



Project / Type

---

Notes

---

Count / Date

---

## Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1

MF	LMF × RSMF × LLMF × LSF	RSMF <sup>a</sup>	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF <sup>a</sup>	Luminaire Maintenance Factor	LSF	Lamp Survival Faktor

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

## Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	3
B13	4
B16	5
B20	6
C10	5
C13	6
C16	8
C20	10