

SONIC sensor direct / indirect asymmetric power

free standing excentric pole
059-7942576P



Project / Type

Notes

Count / Date



General

Floor , Standing

dark grey , RAL 7021 ¹

IP20

indirect 9840 lm

direct 4260 lm

total 14100 lm

LED

3000 K

CRI ≥ 80

L90 / 50000 h

initial MacAdam ≤ 3 SDCM

MR 0.54

MDER 0.49

Optical

Microprismatic

microprismatic

UGR ≤ 16

PstLM ≤ 1.0 ²

SVM ≤ 0.4 ²

Electrical

ESSENTIAL sensor (brightness & presence)

220-240 V

system 105 W

system 134 lm/W³

PC1

Physical

excentric pole 2050 mm


diameter 500 mm

height 2102 mm


7.1 kg

Free standing luminaire with conical luminaire head in die-cast aluminium; round pedestal with recess for table stand; round aluminium upright tube aligned off-centre; surface dark grey powder coated; direct/indirect illumination characteristic; indirect component with special, inclined PCBs for asymmetric radiation characteristic; indirect component covered with clear acrylic glass; direct lighting portion: micro prismatic PMMA cover; perfectly uniform illumination through use of a diffuse polycarbonate-based film; better light dispersion to transparency ratio; UGR ≤ 16; light colour 3000 K; binning initial MacAdam ≤ 3 SDCM; CRI ≥ 80; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; degree of protection IP20; PC1; 220-240 V; luminaire with integrated infrared presence and brightness sensor (ESSENTIAL sensor); automatic light control for individually adjustable brightness; variable automatic shutdown; including TOUCH DIM control for individual control of the brightness; presence sensor detection range ø4,5m on the floor; incl. connection cable (3m) with safety plug; sound absorbing accessories available: acoustic elements made of high quality, self-supporting, at least 50 % recycled PET felt (high acoustic performance by doubling the material) or as an acoustically effective lampshade (large selection of colours) with sound absorbing properties; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

Light distribution



Product drawing



¹ RAL code ² Value of containing product at full load (undimmed)
³ incl. consideration of optical losses, internal control unit losses & operating device efficiency

Installation instructions





Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.95	0.93	0.91	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF ^a	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF ^a	Luminaire Maintenance Factor		LSF	Lamp Survival Factor	

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	21
B13	27
B16	29
C10	35
C13	45
C16	57