

SONIC sensor direct / indirect

free standing excentric pole

059-7922677P



Project / Type

Notes

Count / Date



General

Floor , Standing

white , RAL 9010 ¹

IP20

indirect 5230 lm

direct 5290 lm

total 10520 lm

LED

4000 K

CRI \geq 80

L90 / 50000 h

initial MacAdam \leq 3 SDCM

MR 0.72

MDER 0.66

Optical

Microprismatic

microprismatic

UGR \leq 19

PstLM \leq 1.0 ²

SVM \leq 0.4 ²

Electrical

ESSENTIAL sensor (brightness & presence)

220-240 V

system 69 W

system 152 lm/W³

PC1

Physical

excentric pole 2050 mm

diameter 500 mm


height 2102 mm

7 kg


¹ RAL code ² Value of containing product at full load (undimmed)

³ incl. consideration of optical losses, internal control unit losses & operating device efficiency

Light distribution



Product drawing



Installation instructions





Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.95	0.93	0.91	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF ^a	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF ^a	Luminaire Maintenance Factor		LSF	Lamp Survival Factor	

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	31
B13	40
B16	50
B20	62
B25	78
C10	52
C13	67
C16	85
C20	104
C25	130