

TASK S linear direct / indirect soft

suspended system
059-5756037K



Project / Type _____

Notes _____

Count / Date _____



General

Ceiling , Suspended _____

white , RAL9010 ¹ _____

IP20 _____

indirect 490 lm _____

direct 2860 lm _____

total 3350 lm _____

LED

3000 K _____

CRI ≥ 90 _____

L90 / 50000 h _____

photobio. safety RG 0 - no Risk _____

initial MacAdam ≤ 3 SDCM _____

R_g: 96 , R_r: 90 , R_{t(1-15)}: 90 _____

MR 0.61 _____

MDER 0.56 _____

Optical

Microprismatic _____

UGR < 19 , ≥65° <3000 cd/m² _____

PstLM ≤ 1.0 ² _____

SVM ≤ 0.4 ² _____

Electrical

DALI-2 _____

29.2 W _____

PC1 220-240V _____

115 lm/W _____

1 DALI Addr. _____

Physical

length 1748 mm _____


width 180 mm _____

height 34 mm _____


4.8 kg _____

¹ RAL code ² Value of containing product at full load (undimmed)

Light distribution



Product drawing



Installation instructions



Lighting calculator

