

TASK S direct / indirect soft

suspended

059-5258D38K



Project / Type

Notes

Count / Date



General

Ceiling , Suspended

black , RAL9005 ¹

IP20

indirect 758 lm

direct 4420 lm

total 5180 lm

LED

tunable white

2700 K - 6500 K

CRI ≥ 80

L85 / 50000 h

photobio. safety RG 0 - no Risk

MR 1.01

MDER 0.92

Optical

Microprismatic

UGR < 19 , ≥65° <3000 cd/m²

PstLM ≤ 1.0 ²

SVM ≤ 0.4 ²

Electrical

DALI-2

43 W

PC1 220-240V

120 lm/W

1 DALI Addr.

Physical

cable 1500 mm

length 2315 mm


width 180 mm

height 34 mm


7.3 kg

¹ RAL code ² Value of containing product at full load (undimmed)

Light distribution



Product drawing



Installation instructions



Lighting calculator



TASK S direct / indirect soft

suspended

059-5258D38K



Project / Type

Notes

Count / Date

Maintenance Factors

| Operating Time [h] | 10 000 | 20 000 | 30 000 | 40 000 | 50 000 |
|--------------------|--------|--------|--------|--------|--------|
| LLMF | 0.97 | 0.94 | 0.92 | 0.9 | 0.88 |
| LSF | 1 | 1 | 1 | 1 | 1 |

| | | | |
|------------------|------------------------------|-------------------|---------------------------------|
| MF | LMF × RSMF × LLMF × LSF | RSMF ^a | Room Surface Maintenance Factor |
| MF | Maintenance Factor | LLMF | Lamp Lumens Maintenance Factor |
| LMF ^a | Luminaire Maintenance Factor | LSF | Lamp Survival Faktor |

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

| Automatic Circuit Breaker Type | Number of Fixtures |
|--------------------------------|--------------------|
| B10 | 7 |
| B13 | 10 |
| B16 | 12 |
| B20 | 14 |
| C10 | 10 |
| C13 | 20 |
| C16 | 24 |
| C20 | 28 |

