

LINEA opal / 1 spot

wall

058-6178627BH



Project / Type _____

Notes _____

Count / Date _____



General

Wall , Surface _____

tilt max 89° _____

white , RAL9010 ¹ _____

IP20 _____

172 lm _____

LED

3000 K²-4000 K³ _____

CRI ≥ 97²-90³ _____

L95 / 50000 h²-L85 / 50000 h³ _____

photobio. safety RG 0 - no Risk _____

initial MacAdam ≤ 3 SDCM _____

R_g: 92²-98³ , R_f: 86²-90³ , R₍₁₋₁₅₎: 94²-88³ _____

MR 0.53²-0.76³ _____

MDER 0.48²-0.69³ _____

Optical

Flood _____

beam angle 30° _____

PstLM ≤ 1.0 ⁴ _____

SVM ≤ 0.4 ⁴ _____

High Performance Opal _____

Electrical

non DIM / switch (only spotlights) _____


2.7²-70³ W _____

PC1 220-240V _____

64²-110³ lm/W _____

Light fitting and front cover made of extruded aluminium profile; angular design; no visible screws; surface white powder coated; suitable for wall mounting; homogeneous wall or ceiling illumination through uniform direct/indirect light distribution; direct and indirect light component: HPO (High Performance Opal) cover for uniform illumination; light colour 4000 K; binning initial MacAdam ≤ 3 SDCM; CRI ≥ 97; min. 95% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; degree of protection IP20; PC1 220-240V; photobiological safety according to IEC 62471 risk group RG 0 - no Risk; JUST 26 spotlight module 2,6 W / 159 lm / 3000 K left, incl. switch; incl. converter, non dimmable; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;


Light distribution



flood 30° Spot

h (m)	E0° (lx)	ø (m)
1	419	0.54
2	105	1.09
3	47	1.63
4	26	2.17
5	17	2.72

Product drawing



Physical

length 2510 mm _____

width 40 mm _____

height 100 mm _____

left _____

¹ RAL code ² Spot ³ Linear
⁴ Value of containing product at full load (undimmed)

Installation instructions



LINEA opal / 1 spot

wall

058-6178627BH



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.91	0.89
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF ^a	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF ^a	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	10
B13	12
B16	16
B20	21
C10	17
C13	21
C16	28
C20	35

