

TASK direct / indirect power

free standing T-shape
059-2952057Z



Project / Type _____
Notes _____
Count / Date _____



General

Floor | Standing
white | RAL 9010 ¹
IP20
indirect 7330 lm | direct 2400 lm
total 9730 lm

LED

3000 K
CRI \geq 90
L90 / 50000 h
initial MacAdam \leq 3 SDCM
R_g: 96 | R_r: 90 | R_{t(15)}: 89
MR 0.61 | MDER 0.56

Optical

Microprismatic | microprismatic
UGR \leq 13 | \geq 65° <3000 cd/m²
PstLM \leq 1.0 ² | SVM \leq 0.4 ²

Electrical


touch DIM on pole
PC1 | 220-240 V
system 80 W
system 122 lm/W ³

Physical


T-shape
length 800 mm | width 320 mm | height 1920 mm
11.7 kg

Free standing luminaire with rectangular head with rounded edges in aluminium; extremely flat design (only 15mm); rectangular aluminium tube support; base stand with recess for table stand (T-shape); modern shape in elegant design for discerning requirements; surface white powder coated; direct light distribution through LGP body (Light Guiding Prism); side coupled light directed downwards by laser engraving; indirect light component with special PCBs for increased luminous flux and maximum ceiling illumination; microprismatic PMMA cover; completely homogeneous illumination; UGR \leq 13; VDU compatible workplace luminaire according to DIN EN 12464-1; luminance above 65° \leq 3000 cd/m²; light colour 3000 K; binning initial MacAdam \leq 3 SDCM; CRI \geq 90; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; degree of protection IP20; PC1; 220-240 V; including TOUCH DIM control for individual control of the brightness; incl. connection cable (3m) with safety plug; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

Light distribution



Product drawing



¹ RAL code ² Value of containing product at full load (undimmed)
³ incl. consideration of optical losses, internal control unit losses & operating device efficiency

Installation instructions



TASK direct / indirect power

free standing T-shape
059-2952057Z



Project / Type _____

Notes _____

Count / Date _____

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.97	0.95	0.93	0.92
LSF	1	1	1	1	1

MF	LMF × RSMF × LLMF × LSF	RSMF ^a	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF ^a	Luminaire Maintenance Factor	LSF	Lamp Survival Factor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	8
B13	10
B16	13
B20	16
C10	13
C13	17
C16	22
C20	27