

TASK direct / indirect asymmetric power

free standing T-shape
059-2951157Z



Project / Type _____

Notes _____

Count / Date _____



Free standing luminaire with rectangular head with rounded edges in aluminium; extremely flat design (only 15mm); rectangular aluminium tube support; base stand with recess for table stand (T-shape); modern shape in elegant design for discerning requirements; surface white powder coated; direct light distribution through LGP body (Light Guiding Prism); side coupled light directed downwards by laser engraving; indirect component with special, inclined PCBs for asymmetric radiation characteristic; microprismatic PMMA cover; completely homogeneous illumination; $UGR \leq 13$; VDU compatible workplace luminaire according to DIN EN 12464-1; luminance above $65^\circ \leq 3000 \text{ cd/m}^2$; light colour 4000 K; binning initial MacAdam $\leq 3 \text{ SDCM}$; CRI ≥ 90 ; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; degree of protection IP20; PC1; 220-240 V; including TOUCH DIM control for individual control of the brightness; incl. connection cable (3m) with safety plug; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

Light distribution



Product drawing



General

Floor , Standing _____

white , RAL 9010 ¹ _____

IP20 _____

indirect 11000 lm _____

direct 2030 lm _____

total 13030 lm _____

LED

4000 K _____

CRI ≥ 90 _____

L90 / 50000 h _____

initial MacAdam $\leq 3 \text{ SDCM}$ _____

R_g: 96 , R_f: 90 , R₍₁₋₁₅₎: 87 _____

MR 0.75 _____

MDER 0.68 _____

Optical

Microprismatic _____

microprismatic _____

UGR ≤ 13 , $\geq 65^\circ < 3000 \text{ cd/m}^2$ _____

PstLM ≤ 1.0 ² _____

SVM ≤ 0.4 ² _____

Electrical

touch DIM on pole _____

220-240 V _____

system 95 W _____

system 137 lm/W³ _____

PC1 _____

Physical

T-shape _____

length 800 mm _____

width 320 mm _____

height 1920 mm _____

12.5 kg _____

¹ RAL code ² Value of containing product at full load (undimmed)
³ incl. consideration of optical losses, internal control unit losses
& operating device efficiency

Installation instructions



TASK direct / indirect asymmetric power

free standing T-shape
059-2951157Z



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.97	0.95	0.93	0.92
LSF	1	1	1	1	1

MF

LMF × RSMF × LLMF × LSF

MF

Maintenance Factor

LMF^a

Luminaire Maintenance Factor

RSMF^a

Room Surface Maintenance Factor

LLMF

Lamp Lumens Maintenance Factor

LSF

Lamp Survival Factor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	5
B13	7
B16	9
B20	11
C10	9
C13	11
C16	15
C20	18

