

TASK direct / indirect power

free standing U-shape
059-294205XZ



Project / Type _____

Notes _____

Count / Date _____



Free standing luminaire with rectangular head with rounded edges in aluminium; extremely flat design (only 15mm); rectangular aluminium tube support; base stand with recess for table stand (U-shape); modern shape in elegant design for discerning requirements; surface special colours powder coated; direct light distribution through LGP body (Light Guiding Prism); side coupled light directed downwards by laser engraving; indirect light component with special PCBs for increased luminous flux and maximum ceiling illumination; microprismatic PMMA cover; completely homogeneous illumination; $UGR \leq 13$; VDU compatible workplace luminaire according to DIN EN 12464-1; luminance above $65^\circ \leq 3000 \text{ cd/m}^2$; light colour 3000 K; binning initial MacAdam $\leq 3 \text{ SDCM}$; $CRI \geq 90$; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; degree of protection IP20; PC1; 220-240 V; including TOUCH DIM control for individual control of the brightness; incl. connection cable (3m) with safety plug; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

Light distribution



Product drawing



General

Floor , Standing _____

special colours _____

IP20 _____

indirect 7330 lm _____

direct 2400 lm _____

total 9730 lm _____

LED

3000 K _____

$CRI \geq 90$ _____

L90 / 50000 h _____

initial MacAdam $\leq 3 \text{ SDCM}$ _____

$R_g: 96, R_f: 90, R_{f(1-15)}: 90$ _____

MR 0.61 _____

MDER 0.56 _____

Optical

Microprismatic _____

microprismatic _____

$UGR \leq 13, \geq 65^\circ < 3000 \text{ cd/m}^2$ _____

$P_{stLM} \leq 1.0^1$ _____

$SVM \leq 0.4^1$ _____

Electrical

touch DIM on pole _____

220-240 V _____

system 80 W _____

system 122 lm/W² _____

PC1 _____

Physical

U-shape _____

length 800 mm _____

width 320 mm _____

height 1920 mm _____

10.5 kg _____

¹ Value of containing product at full load (undimmed)
² incl. consideration of optical losses, internal control unit losses & operating device efficiency

Installation instructions



TASK direct / indirect power

free standing U-shape
059-294205XZ



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.97	0.95	0.93	0.92
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF ^a	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF ^a	Luminaire Maintenance Factor		LSF	Lamp Survival Factor	

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	8
B13	10
B16	13
B20	16
C10	13
C13	17
C16	22
C20	27

