

FRAME 60 mid lumen

trim

052-47L461GG



Project / Type

Notes

Count / Date



General

Ceiling , Recessed

grey , RAL9006 ¹

1390 lm/m

IP20

1630 lm

LED

4000 K

CRI ≥ 80

L90 / 50000 h

photobio. safety RG 0 - no Risk

initial MacAdam ≤ 3 SDCM

MR 0.72

MDER 0.65

Optical

Microprismatic

UGR < 19

PstLM ≤ 1.0 ²

SVM ≤ 0.4 ²

Electrical

non DIM

13.3 W

PC1 220-240V

123 lm/W

11 W/m

Physical

trim

length 1193 mm

width 77 mm

height 78 mm

3.2 kg

Cutout

length 1183 mm

width 66 mm


min. ceiling thickness 8 mm

max. ceiling thickness 25 mm

recessed depth 104 mm

¹ RAL code ² Value of containing product at full load (undimmed)

Light distribution



Product drawing



Lighting calculator



FRAME 60 mid lumen

trim

052-47L461GG



Project / Type

Notes

Count / Date

Maintenance Factors

| Operating Time [h] | 10 000 | 20 000 | 30 000 | 40 000 | 50 000 |
|--------------------|------------------------------|--------|-------------------|---------------------------------|--------|
| LLMF | 0.98 | 0.96 | 0.94 | 0.92 | 0.9 |
| LSF | 1 | 1 | 1 | 1 | 1 |
| MF | LMF × RSMF × LLMF × LSF | | RSMF ^a | Room Surface Maintenance Factor | |
| MF | Maintenance Factor | | LLMF | Lamp Lumens Maintenance Factor | |
| LMF ^a | Luminaire Maintenance Factor | | LSF | Lamp Survival Faktor | |

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

| Automatic Circuit Breaker Type | Number of Fixtures |
|--------------------------------|--------------------|
| B10 | 9 |
| B13 | 13 |
| B16 | 15 |
| B20 | 18 |
| C10 | 18 |
| C13 | 26 |
| C16 | 30 |
| C20 | 36 |

Mounting accessories

CONCRETE INSTALLATION HOUSING

| TYPE | L·W·H (MM) | ARTICLE NUMBER(S) |
|---------|------------|-------------------|
| 1235 mm | 1235-75-88 | 035-04126 |

