

MINIMAL 100 mid lumen

trimless

052-33L5517G



Project / Type

Notes

Count / Date



General

Ceiling | Recessed

white | RAL 9016 ¹

IP20

2270 lm

1540 lm/m

LED

3000 K

CRI \geq 80

L90 / 50000 h

initial MacAdam \leq 3 SDCM

MR 0.54 | MDER 0.49

Optical

Microprismatic | microprismatic

UGR \leq 19 | \geq 65° <3000 cd/m²

Electrical

non DIM

PC1 | 220-240 V

system 19.2 W

system 118 lm/W ²

13 W/m

Physical

trimless

length 1476 mm | width 102 mm | height 82 mm

5.5 kg

Cutout

length 1479 mm | width 106 mm

min. ceiling thickness 8 mm | max. ceiling thickness 25 mm


recessed depth 106 mm

¹ RAL code


² incl. consideration of optical losses, internal control unit losses & operating device efficiency

Luminaire housing made of extruded aluminium profile; suitable for rimless installation in plasterboard ceilings; specially designed trim with grooves for better adhesion of smoothing compound; suitable for ceiling thickness of 8-25 mm; surface white powder coated; lighting profile (end cover and mounting bracket pre-assembled) available in advance for installation; remaining lamp components mounted without tools; LED light inset consisting of highly reflective lacquered aluminium for improved thermal management; light colour 3000 K; binning initial MacAdam \leq 3 SDCM; CRI \geq 80; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; micro prismatic PMMA diffuser incl. diffuser film for homogeneous illumination and reduced luminance; UGR \leq 19; VDU compatible workplace luminaire according to DIN EN 12464-1; luminance above 65° \leq 3000 cd/m²; degree of protection IP20; PC1; 220-240 V; internal wiring in light halogen free; incl. converter, non dimmable; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

Light distribution



Product drawing



Installation instructions



Lighting calculator



MINIMAL 100 mid lumen

trimless

052-33L5517G



Project / Type _____

Notes _____

Count / Date _____

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.91	0.9
LSF	1	1	1	1	1

MF	LMF × RSMF × LLMF × LSF	RSMF ^a	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF ^a	Luminaire Maintenance Factor	LSF	Lamp Survival Factor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	15
B13	19
B16	24
B20	30
C10	25
C13	32
C16	40
C20	49

Mounting accessories

CONCRETE INSTALLATION HOUSING

L·W·H (MM)
1535·116·94

ARTICLE NUMBER(S)
036-05156

