



Project / Type
Notes
Count / Date



<b>General</b>
Ceiling / Wall , Semi-Recessed
black , RAL9005 <sup>1</sup>
2040 lm/m
front IP40 , back IP20
2490 lm

<b>LED</b>
4000 K
CRI ≥ 80
L90 / 50000 h
photobio. safety RG 0 - no Risk
initial MacAdam ≤ 3 SDCM
MR 0.72
MDER 0.66

<b>Optical</b>
Jut-Out
PstLM ≤ 1.0 <sup>2</sup>
SVM ≤ 0.4 <sup>2</sup>


<b>Electrical</b>
DALI-2
19.1 W
PC1 220-240V
130 lm/W
1 DALI Addr.
16 W/m

<b>Physical</b>
length 1226 mm
width 89 mm
height 38 mm
3.7 kg

<b>Cutout</b>
length 1234 mm
width 70 mm
min. ceiling thickness 12.5 mm
recessed depth 13 mm

<sup>1</sup> RAL code <sup>2</sup> Value of containing product at full load (undimmed)

Light distribution



Product drawing



Installation instructions



# LENO jut-out

semi-recessed  
051-8514638J



Project / Type

Notes

Count / Date

## Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.95	0.93	0.91	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF <sup>a</sup>	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF <sup>a</sup>	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

## Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	18
B13	24
B16	30
B20	37
C10	31
C13	40
C16	51
C20	62

## Other accessories

### DISMOUNTING TOOL

TYPE	ARTICLE NUMBER(S)
vacuum cup	086-30000

