



Project / Type

Notes

Count / Date



General

Ceiling / Wall , Recessed

white , RAL9016 ¹

1920 lm/m

front IP40 , back IP20

2350 lm

LED

3000 K

CRI ≥ 80

L90 / 50000 h

photobio. safety RG 0 - no Risk

initial MacAdam ≤ 3 SDCM

MR 0.54

MDER 0.49

Optical

Jut-Out

PstLM ≤ 1.0 ²

SVM ≤ 0.4 ²

Electrical

DALI-2

19.1 W

PC2 220-240V

123 lm/W

1 DALI Addr.

16 W/m

Physical

trim

length 1237 mm

width 102 mm

height 23 mm

2.9 kg

Cutout

length 1227 mm

width 92 mm

min. ceiling thickness 12.5 mm


max. ceiling thickness 25 mm

recessed depth 58 mm


recessed depth: 12.5 mm (ceiling) + 45 mm (converter)

¹ RAL code ² Value of containing product at full load (undimmed)

Light distribution



Product drawing



Installation instructions



LENO jut-out

trim

051-8414537J



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.95	0.93	0.91	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF ^a	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF ^a	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	19
B13	24
B16	31
B20	40
C10	31
C13	40
C16	51
C20	66

Other accessories

DISMOUNTING TOOL

TYPE	ARTICLE NUMBER(S)
vacuum cup	086-30000

