

MICROPRISMATIC UGR

< 19

MOVE IT 45
050-3212538P




Project / Type	
Notes	
Count / Date	



Linear light inset made of aluminium; surface anodised black; light inset can be installed and moved without tools by means of magnetic holders+locking; flush with profile system; power supplied via MOVE IT system track profile; hot plug protection; completely homogeneously illuminated, microprismatic PMMA cover; UGR ≤ 19; passive cooling of the LEDs through improved heat sink geometry; with CSP (Chip-Scale-Packaging) technology for maximum efficiency; light colour 3000 K; binning initial MacAdam ≤ 3 SDCM; CRI ≥ 90; min. 85% of luminous flux after 50000 operating hours; energy-efficient high power LEDs with very good colour rendering; degree of protection IP20; PC3; 48 V; DALI single control; flicker-free visual comfort through analogue current control (minimum value 1%); light source not replaceable;

Light distribution



Product drawing



General

Ceiling / Wall Track	
black RAL 9005 ¹	
IP20	
636 lm	
optical inset 99 lm/W ²	

LED

3000 K	
CRI ≥ 90	
L85 / 50000 h	
initial MacAdam ≤ 3 SDCM	
R _g : 99 R _f : 91 R _{f(1-5)} : 89	
MR 0.61 MDER 0.55	

Optical

Microprismatic microprismatic	
UGR ≤ 19	
PstLM ≤ 1.0 ³ SVM ≤ 0.4 ³	

Electrical

DALI-2 1 DALI Addr.	
PC3 48 V	
fixture 9.2 W	
optical inset 6.4 W	

Physical

length 605 mm width 43 mm height 48 mm	
0.55 kg	

¹ RAL code ² incl. consideration of optical losses
³ Value of containing product at full load (undimmed)

Installation instructions



MICROPRISMATIC UGR

< 19

MOVE IT 45
050-3212538P



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.95	0.92	0.9	0.87
LSF	1	1	1	1	1

MF

MF

LMF^a

LMF × RSMF × LLMF × LSF

Maintenance Factor

Luminaire Maintenance Factor

RSMF^a

LLMF

LSF

Room Surface Maintenance Factor

Lamp Lumens Maintenance Factor

Lamp Survival Factor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

