



Project / Type _____

Notes _____

Count / Date _____



General	
Ceiling / Wall , Track	_____
rotation 360°	_____
black , RAL9005 ¹	_____
1980 lm/m	_____
IP20	_____
1190 lm	_____


LED	
2700 K	_____
CRI ≥ 80	_____
L90 / 50000 h	_____
photobio. safety RG 0 - no Risk	_____
initial MacAdam ≤ 3 SDCM	_____
MR 0.47	_____
MDER 0.42	_____

Electrical	
DALI-2	_____
10.6 W	_____
PC3 48V	_____
112 lm/W	_____
1 DALI Addr.	_____
18 W/m	_____


Physical	
length 610 mm	_____
width 33 mm	_____
height 33 mm	_____
0.3 kg	_____

¹ RAL code

Light distribution



Product drawing



Installation instructions





Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.95	0.93	0.91	0.9
LSF	1	1	1	1	1

MF

MF

LMF^a

LMF × RSMF × LLMF × LSF

Maintenance Factor

Luminaire Maintenance Factor

RSMF^a

LLMF

LSF

Room Surface Maintenance Factor

Lamp Lumens Maintenance Factor

Lamp Survival Faktor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.