

WALLWASHER FLUSH

MOVE IT 25

050-0218438A




Project / Type	
Notes	
Count / Date	



Linear light inset made of aluminium; surface anodised black; light inset can be installed and moved without tools by means of magnetic holders+locking; flush with profile system; power supplied via MOVE IT system track profile; hot plug protection; with specially computed, asymmetric lens for homogeneous vertical lighting intensity; optical attachment available as accessory; accessories are listed separately; passive cooling of the LEDs through improved heat sink geometry; with CSP (Chip-Scale-Packaging) technology for maximum efficiency; light colour 2700 K; binning initial MacAdam ≤ 3 SDCM; CRI ≥ 90 ; min. 80% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; degree of protection IP20; PC3; 48 V; DALI single control; flicker-free visual comfort through analogue current control (minimum value 1%); light source not replaceable;

Light distribution



Product drawing



General

Ceiling / Wall , Track	
black , RAL 9005 ¹	
IP20	
3320 lm	
optical inset 106 lm/W ²	

LED

2700 K	
CRI ≥ 90	
L80 / 50000 h	
initial MacAdam ≤ 3 SDCM	
R _g : 95 , R _r : 92 , R _{t(1-15)} : 90	
MR 0.45	
MDER 0.41	

Optical

wallwasher	
PstLM ≤ 1.0 ³	
SVM ≤ 0.4 ³	

Electrical

DALI-2 single control	
48 V	
fixture 45 W	
optical inset 31 W	
PC3	
1 DALI Addr.	

Physical

length 2405 mm	
width 25 mm	
height 45 mm	
1.5 kg	

¹ RAL code ² incl. consideration of optical losses
³ Value of containing product at full load (undimmed)

Installation instructions



WALLWASHER FLUSH

MOVE IT 25
050-0218438A



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.96	0.93	0.89	0.86	0.83
LSF	1	1	1	1	1

MF

MF

LMF^a

LMF × RSMF × LLMF × LSF

Maintenance Factor

Luminaire Maintenance Factor

RSMF^a

LLMF

LSF

Room Surface Maintenance Factor

Lamp Lumens Maintenance Factor

Lamp Survival Factor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

