

TULA nano suspended

canopy trim


049-5710417M 005-3521017 002-90732



Project / Type _____

Notes _____

Count / Date _____



General

Ceiling | Suspended _____

white | RAL 9016 ¹ _____

Canopy traffic white _____

IP20 _____

699 lm _____

fixture 78 lm/W ² _____

LED

2700 K _____

CRI ≥ 90 _____

initial MacAdam ≤ 3 SDCM _____

R_g: 99 | R_f: 91 | R_(f-15): 89 _____

MR 0.53 | MDER 0.48 _____

Optical

medium | beam angle 25° _____

PstLM ≤ 1.0 ³ | SVM ≤ 0.4 ³ _____

Electrical

non DIM _____

PC2 | 220-240 V _____

system 12.0 W | fixture 9.0 W _____

18 Vf | 500 mA _____

Physical

diameter 26 mm | height 500 mm _____

0.43 kg _____

Cutout

diameter 65 mm _____

min. ceiling thickness 2 mm | max. ceiling thickness 25 mm _____

recessed depth 70 mm _____

¹ RAL code
² incl. consideration of optical losses & internal control unit losses
³ Value of containing product at full load (undimmed)


Light distribution



medium 25°

h (m)	E0° (lx)	ø (m)
1	2620	0.44
2	660	0.89
3	290	1.33
4	160	1.77
5	100	2.22

Product drawing



Installation instructions



Lighting calculator

