

SPADO 150 square downlight

trim

049-31516370



Project / Type

Notes

Count / Date



General

Ceiling , Recessed

white , RAL9016 ¹

front IP44 , back IP20

1940 lm

LED

4000 K

CRI \geq 80

L80 / 50000 h

initial MacAdam \leq 3 SDCM

MR 0.72

MDER 0.66

Optical

beam angle 56°

UGR < 19 , $\geq 65^\circ < 1500$ cd/m²

PstLM ≤ 1.0 ²

SVM ≤ 0.4 ²

Electrical

DALI-2

16.4 W

PC2 220-240V

118 lm/W

1 DALI Addr.

Physical

trim

length 179 mm

width 179 mm

height 104 mm

0.8 kg

Cutout

length 150 mm

width 150 mm


min. ceiling thickness 2 mm

max. ceiling thickness 25 mm


recessed depth 110 mm

¹ RAL code ² Value of containing product at full load (undimmed)

Light distribution



Product drawing



Installation instructions



Lighting calculator



SPADO 150 square downlight

trim
049-31516370



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.97	0.93	0.89	0.86	0.82
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF ^a	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF ^a	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	19
B13	24
B16	31
B20	40
C10	31
C13	40
C16	51
C20	66

Mounting accessories

EXPOSED CONCRETE MOUNTING ACCESSORY

L-W-H (MM)	ARTICLE NUMBER(S)
400-260-160	049-3192210



PRIMED CONCRETE MOUNTING ACCESSORY

ARTICLE NUMBER(S)
049-3191410

