

SPADO 150 round downlight

trim
049-31236180



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.95	0.93	0.91	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF ^a	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF ^a	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	34
B13	43
B16	54
B20	67
C10	56
C13	72
C16	91
C20	112

Mounting accessories

EXPOSED CONCRETE MOUNTING ACCESSORY

L·W·H (MM)	ARTICLE NUMBER(S)
295·295·160	049-3191210



PRIMED CONCRETE MOUNTING ACCESSORY

ARTICLE NUMBER(S)
049-3191410

