

MINO 60 mid lumen

suspended

046-42L3618H



| | |
|----------------|--|
| Project / Type | |
| Notes | |
| Count / Date | |



General

| |
|-------------------------------|
| Ceiling , Suspended |
| black , RAL 9005 ¹ |
| IP20 |
| 1400 lm |
| 1610 lm/m |

LED

| |
|--------------------------|
| 4000 K |
| CRI ≥ 80 |
| L90 / 50000 h |
| initial MacAdam ≤ 3 SDCM |
| MR 0.72 |
| MDER 0.65 |

Optical

| |
|--------------------------|
| High Performance Opal |
| opal (lambertsch) |
| PstLM ≤ 1.0 ² |
| SVM ≤ 0.4 ² |

Electrical

| |
|------------------------------|
| non DIM |
| 220-240 V |
| system 10.3 W |
| system 136 lm/W ³ |
| PC1 |
| 12 W/m |

Physical

| |
|---------------|
| cable 1500 mm |
| length 880 mm |
| width 60 mm |
| height 80 mm |
| 2.71 kg |

Luminaire housing made of extruded aluminium profile; light tight final end caps made of aluminium; no visible screws; angular design; surface black powder coated; suspended luminaire with 1500mm cable suspension; with integrated toolless suspension height adjustment on the luminaire; spring clip attachment to the luminaire; freely positionable; incl. feed (black); lighting profile (end cover pre-assembled) available in advance for installation; remaining lamp components mounted without tools; LED light inset consisting of highly reflective lacquered aluminium for improved thermal management; light colour 4000 K; binning initial MacAdam ≤ 3 SDCM; CRI ≥ 80; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; HPO (High Performance Opal) cover for uniform illumination; degree of protection IP20; PC1; 220-240 V; internal wiring in light halogen free; incl. converter, non dimmable; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

Light distribution



Product drawing



¹ RAL code ² Value of containing product at full load (undimmed)
³ incl. consideration of optical losses, internal control unit losses & operating device efficiency

Installation instructions



Lighting calculator



MINO 60 mid lumen

suspended

046-42L3618H



Project / Type

Notes

Count / Date

Maintenance Factors

| Operating Time [h] | 10 000 | 20 000 | 30 000 | 40 000 | 50 000 |
|--------------------|------------------------------|--------|-------------------|---------------------------------|--------|
| LLMF | 0.98 | 0.96 | 0.94 | 0.92 | 0.9 |
| LSF | 1 | 1 | 1 | 1 | 1 |
| MF | LMF × RSMF × LLMF × LSF | | RSMF ^a | Room Surface Maintenance Factor | |
| MF | Maintenance Factor | | LLMF | Lamp Lumens Maintenance Factor | |
| LMF ^a | Luminaire Maintenance Factor | | LSF | Lamp Survival Factor | |

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

| Automatic Circuit Breaker Type | Number of Fixtures |
|--------------------------------|--------------------|
| B10 | 9 |
| B13 | 13 |
| B16 | 15 |
| B20 | 18 |
| C10 | 18 |
| C13 | 26 |
| C16 | 30 |
| C20 | 36 |

