

# BASO 40 microprismatic

trimless

045-0724610Z



Project / Type	
Notes	
Count / Date	



## General

Ceiling , Recessed
aluminium raw
IP20
2500 lm
2090 lm/m

## LED

4000 K
CRI $\geq 80$
L90 / 50000 h
initial MacAdam $\leq 3$ SDCM
MR 0.72
MDER 0.66

## Optical

Microprismatic
microprismatic
PstLM $\leq 1.0$ <sup>1</sup>
SVM $\leq 0.4$ <sup>1</sup>

## Electrical

non DIM
220-240 V
system 27.5 W
system 91 lm/W <sup>2</sup>
PC1
23 W/m


## Physical

trimless
length 1220 mm
width 40 mm
height 75 mm
2 kg


## Cutout

length 1208 mm
width 48 mm
min. ceiling thickness 8 mm
max. ceiling thickness 20 mm
recessed depth 76 mm

## Light distribution



## Product drawing



<sup>1</sup> Value of containing product at full load (undimmed)  
<sup>2</sup> incl. consideration of optical losses, internal control unit losses & operating device efficiency

## Installation instructions



## Lighting calculator



# BASO 40 microprismatic

trimless

045-0724610Z



Project / Type

Notes

Count / Date

## Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.95	0.93	0.91	0.9
LSF	1	1	1	1	1

MF

MF

LMF<sup>a</sup>

LMF × RSMF × LLMF × LSF

Maintenance Factor

Luminaire Maintenance Factor

RSMF<sup>a</sup>

LLMF

LSF

Room Surface Maintenance Factor

Lamp Lumens Maintenance Factor

Lamp Survival Factor

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

## Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	22
B13	29
B16	36
B20	45
C10	37
C13	48
C16	61
C20	76

