

# MINO 60 CIRCLE 1500

direct / indirect

suspended

034-2411537Z



Project / Type

Notes

Count / Date



## General

Ceiling , Suspended

white , RAL 9010 <sup>1</sup>

IP20

indirect 4820 lm

direct 9130 lm

total 13950 lm

## LED

3000 K

CRI  $\geq$  80

L90 / 50000 h

initial MacAdam  $\leq$  3 SDCM

MR 0.56

MDER 0.51

## Optical

Microprismatic

microprismatic

UGR  $\leq$  19

PstLM  $\leq$  1.0<sup>2 3</sup>

SVM  $\leq$  0.4<sup>2 3</sup>

## Electrical

DALI-2

220-240 V

system 114 W

system 122 lm/W<sup>4</sup>

PC1

5 DALI Addr.

## Physical

cable 1500 mm / canopy central

diameter 1560 mm

height 80 mm

centerline radius 750 mm


14 kg

<sup>1</sup> RAL code <sup>2</sup> combined


<sup>3</sup> Value of containing product at full load (undimmed)

<sup>4</sup> incl. consideration of optical losses, internal control unit losses & operating device efficiency

## Light distribution



## Product drawing



\*canopy central version

## Installation instructions



## Lighting calculator



[034-2411537Z] The technical data represent rated values for an ambient temperature of 25°C. The data values for the luminous flux are initially subject to a tolerance of +/- 10%, those for the electrical connected load are initially subject to a tolerance of +/- 10%, and those for the colour temperature are initially subject to a tolerance of +/- 150 K. No liability is assumed for typographical or printing errors. The general terms and conditions of XAL GmbH apply.  
© XAL GmbH · Auer-Welsbach-Gasse 36 · 8055 Graz · Austria · www.xal.com

02.05.2025

# MINO 60 CIRCLE 1500

direct / indirect

suspended  
034-2411537Z



Project / Type \_\_\_\_\_

Notes \_\_\_\_\_

Count / Date \_\_\_\_\_

## Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF <sup>a</sup>	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF <sup>a</sup>	Luminaire Maintenance Factor		LSF	Lamp Survival Factor	

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

## Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	3
B13	4
B16	5
B20	7
C10	6
C13	7
C16	9
C20	11

## Acoustic accessories

### MINO CIRCLE ACOUSTIC 1500 inlay

COLOUR	Ø (MM)	ARTICLE NUMBER(S)
marble grey	1434	034-270211D
black	1434	034-270211L
white	1434	034-270211W

