

MINO 60 CIRCLE 1500

direct / indirect

suspended
034-2211638Z



Project / Type _____


Notes _____

Count / Date _____




Ring-shaped light fitting in rolled and seamlessly welded extruded aluminium profile; suspended luminaire with 1500mm cable suspension; with integrated toolless suspension height adjustment on the luminaire; incl. feed (black); surface black powder coated; LED light inset consisting of highly reflective lacquered aluminium for improved thermal management; light colour 4000 K; binning initial MacAdam ≤ 3 SDCM; CRI ≥ 80 ; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; micro prismatic PMMA diffuser incl. diffuser film for homogeneous illumination and reduced luminance; direct/indirect light emission for additional accentuation of the ceiling; indirect light component with special PCBs for increased luminous flux and maximum ceiling illumination; degree of protection IP20; PC1; 220-240 V; internal wiring in light halogen free; incl. DALI-2 converter; sound absorbing accessories available; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

Light distribution



Product drawing



General

Ceiling | Suspended _____

black | RAL 9005 ¹ _____

IP20 _____

indirect 5490 lm | direct 10400 lm _____

total 15900 lm _____

LED

4000 K _____

CRI ≥ 80 _____

L90 / 50000 h _____

initial MacAdam ≤ 3 SDCM _____

MR 0.72 | MDER 0.65 _____

Optical

Microprismatic | microprismatic _____

PstLM $\leq 1.0^2$ ³ | SVM $\leq 0.4^2$ ³ _____

Electrical

DALI-2 | 5 DALI Addr. _____

PC1 | 220-240 V _____

system 114 W _____

system 139 lm/W ⁴ _____

Physical

cable 1500 mm _____

diameter 1560 mm | height 80 mm _____

centerline radius 750 mm _____

13 kg _____

¹ RAL code ² combined
³ Value of containing product at full load (undimmed)
⁴ incl. consideration of optical losses, internal control unit losses & operating device efficiency

Installation instructions



MINO 60 CIRCLE 1500

direct / indirect

suspended
034-2211638Z



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF ^a	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF ^a	Luminaire Maintenance Factor		LSF	Lamp Survival Factor	

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	3
B13	4
B16	5
B20	7
C10	6
C13	7
C16	9
C20	11

Acoustic accessories

MINO CIRCLE ACOUSTIC 1500 inlay

COLOUR	Ø (MM)	ARTICLE NUMBER(S)
marble grey	1434	034-270211D
black	1434	034-270211L
white	1434	034-270211W
anthracite	1434	034-270211B
limestone	1434	034-270211S

