

POWER SUPPLY SUSPENDED

058-6592217



Project / Type _____

Notes _____

Count / Date _____



General
traffic white , RAL 9016 ¹ _____

Electrical
non DIM _____
PC2 _____
100 W _____
non DIM _____
min 176 V _____
max 264 V _____
η 92 % _____
Constant Voltage _____
min 50 Hz _____
max 60 Hz _____

Physical
suspended _____

¹ RAL code



POWER SUPPLY SUSPENDED

058-6592217



Project / Type

Notes

Count / Date

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Converters
B13	8
B16	10
B20	12
C13	13
C16	17
C20	20

