

# MINO 60 high lumen

ceiling offset

046-47M553GH



Project / Type \_\_\_\_\_

Notes \_\_\_\_\_

Count / Date \_\_\_\_\_



## General

Ceiling , Surface \_\_\_\_\_

grey , RAL9006 <sup>1</sup> \_\_\_\_\_

1940 lm/m \_\_\_\_\_

IP20 \_\_\_\_\_

Ball impact resistant DIN 18032-3 \_\_\_\_\_

2850 lm \_\_\_\_\_

## LED

3000 K \_\_\_\_\_

CRI ≥ 80 \_\_\_\_\_

L90 / 50000 h \_\_\_\_\_

photobio. safety RG 0 - no Risk \_\_\_\_\_

initial MacAdam ≤ 3 SDCM \_\_\_\_\_

MR 0.56 \_\_\_\_\_

MDER 0.51 \_\_\_\_\_

## Optical

High Performance Opal \_\_\_\_\_

PstLM ≤ 1.0 <sup>2</sup> \_\_\_\_\_

SVM ≤ 0.4 <sup>2</sup> \_\_\_\_\_

## Electrical

DALI-2 \_\_\_\_\_

29.1 W \_\_\_\_\_

PC1 220-240V \_\_\_\_\_

98 lm/W \_\_\_\_\_

1 DALI Addr. \_\_\_\_\_

20 W/m \_\_\_\_\_

## Physical

length 1475 mm \_\_\_\_\_


width 60 mm \_\_\_\_\_

height 90 mm \_\_\_\_\_

3.8 kg \_\_\_\_\_

<sup>1</sup> RAL code <sup>2</sup> Value of containing product at full load (undimmed)

## Light distribution



## Product drawing



## Installation instructions



## Lighting calculator



# MINO 60 high lumen

ceiling offset  
046-47M553GH



Project / Type

Notes

Count / Date

## Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF <sup>a</sup>	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF <sup>a</sup>	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

## Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	7
B13	10
B16	12
B20	14
C10	10
C13	20
C16	24
C20	28

