

# FRAME 60 mid lumen

trim


052-47L8017G



Project / Type

Notes

Count / Date



## General

Ceiling | Recessed

traffic white | RAL 9016 <sup>1</sup>

IP20

2470 lm

1050 lm/m

## LED

3000 K

CRI  $\geq$  90

L90 / 50000 h

initial MacAdam  $\leq$  3 SDCM

R<sub>g</sub>: 99 | R<sub>r</sub>: 91 | R<sub>(f-15)</sub>: 89

MR 0.61 | MDER 0.55

## Optical

Microprismatic | microprismatic

UGR  $\leq$  19 |  $\geq 65^\circ$  < 3000 cd/m<sup>2</sup>

## Electrical

non DIM

PC1 | 220-240 V

system 26.6 W

system 93 lm/W <sup>2</sup>

11 W/m

## Physical

trim

length 2365 mm | width 77 mm | height 78 mm

5,8 kg

## Cutout

length 2355 mm | width 66 mm

min. ceiling thickness 8 mm | max. ceiling thickness 25 mm


recessed depth 104 mm

<sup>1</sup> RAL code


<sup>2</sup> incl. consideration of optical losses, internal control unit losses & operating device efficiency

Luminaire housing made of extruded aluminium profile; recessed light with wrap around edge; suitable for ceiling thickness of 8-25 mm; surface traffic white powder coated; lighting profile (end cover and mounting bracket pre-assembled) available in advance for installation; remaining lamp components mounted without tools; LED light inset consisting of highly reflective lacquered aluminium for improved thermal management; light colour 3000 K; binning initial MacAdam  $\leq$  3 SDCM; CRI  $\geq$  90; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; micro prismatic PMMA diffuser incl. diffuser film for homogeneous illumination and reduced luminance; UGR  $\leq$  19; VDU compatible workplace luminaire according to DIN EN 12464-1; luminance above  $65^\circ \leq$  3000 cd/m<sup>2</sup>; degree of protection IP20; PC1; 220-240 V; internal wiring in light halogen free; incl. converter, non dimmable; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

## Light distribution



## Product drawing



## Installation instructions



## Lighting calculator



# FRAME 60 mid lumen

trim

052-47L8017G



Project / Type

Notes

Count / Date

## Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1

MF	LMF × RSMF × LLMF × LSF	RSMF <sup>a</sup>	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF <sup>a</sup>	Luminaire Maintenance Factor	LSF	Lamp Survival Factor

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

## Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	15
B13	19
B16	24
B20	30
C10	25
C13	32
C16	40
C20	49

## Mounting accessories

### CONCRETE INSTALLATION HOUSING

L·W·H (MM)  
2407-75-88

ARTICLE NUMBER(S)  
035-04236

