

MINO 60 S CIRCLE

1000 direct / indirect

suspended

034-741363GH



Project / Type	
Notes	
Count / Date	



General

Ceiling , Suspended	
grey , RAL9006 ¹	
IP20	
indirect 3550 lm	
direct 7300 lm	
total 10850 lm	

LED

4000 K	
CRI ≥ 80	
L90 / 50000 h	
photobio. safety RG 0 - no Risk	
initial MacAdam ≤ 3 SDCM	
MR 0.72	
MDER 0.65	

Optical

High Performance Opal	
PstLM ≤ 1.0 ²	
SVM ≤ 0.4 ²	

Electrical

DALI-2	
84 W	
PC1 220-240V	
129 lm/W	
2 DALI Addr.	

Physical

cable 1500 mm / canopy central	
length 1060 mm	
width 60 mm	
height 60 mm	
centerline radius 500 mm	
9 kg	


¹ RAL code ² Value of containing product at full load (undimmed)

Lighting calculator




Ring-shaped light fitting in rolled and seamlessly welded extruded aluminium profile; flat design; suspended luminaire with 1500mm cable suspension (canopy central); height adjustment without tools; incl. feeder cable; surface grey powder coated; extruded profile for improved thermal management; light colour 4000 K; binning initial MacAdam ≤ 3 SDCM; CRI ≥ 80; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; HPO (High Performance Opal) cover for uniform illumination; direct/indirect light emission for additional accentuation of the ceiling; indirect light component with integrated PC boards and high quality lens system for maximum, homogeneous ceiling illumination; degree of protection IP20; PC1 220-240V; photobiological safety according to IEC 62471 risk group RG 0 - no Risk; incl. DALI-2 converter; converter included in canopy; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

Light distribution



Product drawing



[034-741363GH] The technical data represent rated values for an ambient temperature of 25°C. The data values for the luminous flux are initially subject to a tolerance of +/- 10%, those for the electrical connected load are initially subject to a tolerance of +/- 10%, and those for the colour temperature are initially subject to a tolerance of +/- 150 K. No liability is assumed for typographical or printing errors. The general terms and conditions of XAL GmbH apply.
© XAL GmbH · Auer-Welsbach-Gasse 36 · 8055 Graz · Austria · www.xal.com

09.05.2024

MINO 60 S CIRCLE

1000 direct / indirect

suspended
034-741363GH



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1

MF

MF

LMF^a

LMF × RSMF × LLMF × LSF

Maintenance Factor

Luminaire Maintenance Factor

RSMF^a

LLMF

LSF

Room Surface Maintenance Factor

Lamp Lumens Maintenance Factor

Lamp Survival Faktor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	4
B13	5
B16	7
B20	8
C10	7
C13	9
C16	12
C20	15

