

# MINO 60 S CIRCLE

## 1000 direct / indirect

suspended

034-741353GH



Project / Type	
Notes	
Count / Date	



### General

Ceiling , Suspended	
grey , RAL9006 <sup>1</sup>	
IP20	
indirect 3120 lm	
direct 6420 lm	
total 9540 lm	

### LED

3000 K	
CRI ≥ 80	
L90 / 50000 h	
photobio. safety RG 0 - no Risk	
initial MacAdam ≤ 3 SDCM	
MR 0.56	
MDER 0.51	

### Optical

High Performance Opal	
PstLM ≤ 1.0 <sup>2</sup>	
SVM ≤ 0.4 <sup>2</sup>	

### Electrical

DALI-2	
84 W	
PC1 220-240V	
114 lm/W	
2 DALI Addr.	

### Physical

cable 1500 mm / canopy central	
length 1060 mm	
width 60 mm	
height 60 mm	
centerline radius 500 mm	
9 kg	


<sup>1</sup> RAL code <sup>2</sup> Value of containing product at full load (undimmed)

### Lighting calculator




Ring-shaped light fitting in rolled and seamlessly welded extruded aluminium profile; flat design; suspended luminaire with 1500mm cable suspension (canopy central); height adjustment without tools; incl. feeder cable; surface grey powder coated; extruded profile for improved thermal management; light colour 3000 K; binning initial MacAdam ≤ 3 SDCM; CRI ≥ 80; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; HPO (High Performance Opal) cover for uniform illumination; direct/indirect light emission for additional accentuation of the ceiling; indirect light component with integrated PC boards and high quality lens system for maximum, homogeneous ceiling illumination; degree of protection IP20; PC1 220-240V; photobiological safety according to IEC 62471 risk group RG 0 - no Risk; incl. DALI-2 converter; converter included in canopy; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

### Light distribution



### Product drawing



# MINO 60 S CIRCLE

## 1000 direct / indirect

suspended  
034-741353GH



Project / Type

Notes

Count / Date

### Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF <sup>a</sup>	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF <sup>a</sup>	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

### Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	4
B13	5
B16	7
B20	8
C10	7
C13	9
C16	12
C20	15

