

MINO 60 S CIRCLE

1000 direct

suspended
034-7412637H



Project / Type _____

Notes _____

Count / Date _____



Ring-shaped light fitting in rolled and seamlessly welded extruded aluminium profile; flat design; suspended luminaire with 1500mm cable suspension (canopy central); height adjustment without tools; incl. feed (white); surface white powder coated; extruded profile for improved thermal management; light colour 4000 K; binning initial MacAdam ≤ 3 SDCM; CRI ≥ 80 ; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; HPO (High Performance Opal) cover for uniform illumination; degree of protection IP20; PC1; 220-240 V; incl. DALI-2 converter; converter included in canopy; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;



General

Ceiling | Suspended _____

white | RAL 9010 ¹ _____

IP20 _____

7300 lm _____

LED

4000 K _____

CRI ≥ 80 _____

L90 / 50000 h _____

initial MacAdam ≤ 3 SDCM _____

MR 0.72 | MDER 0.65 _____

Optical

High Performance Opal | opal (lambertsch) _____

PstLM ≤ 1.0 ² | SVM ≤ 0.4 ² _____

Electrical

DALI-2 | 1 DALI Addr. _____

PC1 | 220-240 V _____

system 59 W _____

system 124 lm/W ³ _____

Physical


cable 1500 mm / canopy central _____

diameter 1060 mm | height 60 mm _____


centerline radius 500 mm _____

¹ RAL code ² Value of containing product at full load (undimmed)
³ incl. consideration of optical losses, internal control unit losses & operating device efficiency

Light distribution



Product drawing



Installation instructions



Lighting calculator



MINO 60 S CIRCLE

1000 direct

suspended
034-7412637H



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF ^a	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF ^a	Luminaire Maintenance Factor		LSF	Lamp Survival Factor	

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	6
B13	8
B16	10
B20	12
C10	10
C13	13
C16	16
C20	20

