

LOUVER WIDE

MOVE IT PRO
086-6450934X



Project / Type


Notes

Count / Date



Linear light inset made of plastic; light inset, incl. high power adapter + converter can be installed flexibly and without tools; flush with profile system; power supplied via MOVE IT PRO system track profile; high quality reflector with micro-faceted, aluminum-vaporised surface; chrome reflector; precise radiation characteristic with symmetrical light distribution; for use in schools and offices; $UGR \leq 19$; VDU compatible workplace luminaire according to DIN EN 12464-1; luminance above $65^\circ \leq 1500 \text{ cd/m}^2$; passive cooling of the LEDs through improved heat sink geometry; light colour 2700 K; binning initial MacAdam $\leq 3 \text{ SDCM}$; CRI ≥ 90 ; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; degree of protection IP20; PC2 220-240V; DALI single control; flicker-free visual comfort through analogue current control (minimum value 1%); light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

Light distribution



Product drawing



General

Ceiling , Track

reflector wide

chrome reflector

2220 lm/m

IP20

6670 lm

LED

2700 K

CRI ≥ 90

L90 / 50000 h

initial MacAdam $\leq 3 \text{ SDCM}$

$R_g: 101, R_r: 90, R_{t1-15}: 88$

MR 0.51

MDER 0.46

Optical

super wide flood

$UGR < 19, \geq 65^\circ < 1500 \text{ cd/m}^2$

Electrical

DALI-2

47 W

PC2 220-240V

142 lm/W

1 DALI Addr.

16 W/m

Physical

length 3000 mm

width 43 mm

height 13 mm

Lighting calculator



LOUVER WIDE

MOVE IT PRO
086-6450934X



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1

MF

MF

LMF^a

LMF × RSMF × LLMF × LSF

Maintenance Factor

Luminaire Maintenance Factor

RSMF^a

LLMF

LSF

Room Surface Maintenance Factor

Lamp Lumens Maintenance Factor

Lamp Survival Faktor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

