

# LOUVER WIDE

MOVE IT PRO  
086-6420634X



Project / Type

Notes

Count / Date



General

Ceiling , Track

reflector wide

chrome reflector

2940 lm/m

IP20

4400 lm

LED

4000 K

CRI ≥ 80

L90 / 50000 h

initial MacAdam ≤ 3 SDCM

MR 0.72

MDER 0.65

Optical

super wide flood

UGR < 19 , ≥65° <1500 cd/m²

PstLM ≤ 1.0 <sup>1</sup>

SVM ≤ 0.4 <sup>1</sup>

Electrical

DALI-2

25.1 W

PC2 220-240V

175 lm/W

1 DALI Addr.

17 W/m

Physical


length 1500 mm

width 43 mm

height 13 mm

<sup>1</sup> Value of containing product at full load (undimmed)

## Light distribution



## Product drawing



## Lighting calculator



# LOUVER WIDE

MOVE IT PRO  
086-6420634X



Project / Type

Notes

Count / Date

### Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF <sup>a</sup>	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF <sup>a</sup>	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

### Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	17
B13	22
B16	28
C10	22
C13	27
C16	35

