

# INDIRECT EXTENSION

## low power MOVE IT PRO

086-6800530B



Project / Type


Notes

Count / Date



Linear light inset made of plastic; light inset can be installed flexibly and without tools; flush with profile system; power supplied via INDIRECT MOVE IT PRO inset; with indirect light component for additional accentuation of the ceiling; high quality lens system for maximum, homogeneous ceiling illumination; passive cooling of the LEDs through improved heat sink geometry; light colour 3000 K; binning initial MacAdam  $\leq 3$  SDCM; CRI  $\geq 80$ ; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; degree of protection IP20; PC3; light source replaceable by an authorized professional;

### Light distribution



### Product drawing



### General

Ceiling | Track Suspended

white

IP20

374 lm

### LED

3000 K

CRI  $\geq 80$

L90 / 50000 h

initial MacAdam  $\leq 3$  SDCM

MR 0.56 | MDER 0.51

### Optical

batwing

UGR  $\leq 10$  |  $\geq 65^\circ$   $<1500$  cd/m<sup>2</sup>

### Electrical

system 2.8 W | fixture 2.4 W

system 134 lm/W <sup>1</sup>

50 mA

PC3

### Physical

length 245 mm | width 24 mm | height 6 mm

0.04 kg

<sup>1</sup> incl. consideration of optical losses, internal control unit losses & operating device efficiency

### Installation instructions



### Lighting calculator



# INDIRECT EXTENSION

## low power MOVE IT PRO

086-6800530B



Project / Type

Notes

Count / Date

### Maintenance Factors

| Operating Time [h] | 10 000 | 20 000 | 30 000 | 40 000 | 50 000 |
|--------------------|--------|--------|--------|--------|--------|
| LLMF               | 0.98   | 0.96   | 0.94   | 0.92   | 0.9    |
| LSF                | 1      | 1      | 1      | 1      | 1      |

MF

MF

LMF<sup>a</sup>

LMF × RSMF × LLMF × LSF

Maintenance Factor

Luminaire Maintenance Factor

RSMF<sup>a</sup>

LLMF

LSF

Room Surface Maintenance Factor

Lamp Lumens Maintenance Factor

Lamp Survival Factor

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

