

MINO 40 mid lumen

suspended


042-1212037Z



Project / Type

Notes

Count / Date



General

Ceiling | Suspended
RAL Pure white | RAL 9010
IP20
1200 lm
1200 lm/m

LED

3000 K
CRI \geq 90
L90 / 50000 h
initial MacAdam \leq 3 SDCM
 R_g : 99 | R_r : 91 | $R_{f(15)}$: 89
MR 0.61 | MDER 0.55

Optical

Microprismatic | microprismatic
 $PstLM \leq 1.0$ ¹ | $SVM \leq 0.4$ ¹

Electrical


DALI-2 | 1 DALI Addr.
PC1 | 220-240 V
system 12.1 W
system 99 lm/W ²
12 W/m

Physical


length 1008 mm | width 40 mm | height 65 mm
4.6 kg

Luminaire housing made of extruded aluminium profile; light tight final end caps made of aluminium; no visible screws; angular design; surface pure white powder coated; suspended luminaire with 1500mm cable suspension; height adjustment without tools; incl. feed (white); luminaire profile can be pre-mounted; remaining lamp components mounted without tools; LED light inset consisting of highly reflective lacquered aluminium for improved thermal management; light colour 3000 K; binning initial MacAdam \leq 3 SDCM; CRI \geq 90; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; micro prismatic PMMA diffuser incl. diffuser film for homogeneous illumination and reduced luminance; degree of protection IP20; PC1; 220-240 V; internal wiring in light halogen free; incl. DALI-2 converter; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

Light distribution



Product drawing



¹ Value of containing product at full load (undimmed)
² incl. consideration of optical losses, internal control unit losses & operating device efficiency

Installation instructions



Lighting calculator



MINO 40 mid lumen

suspended

042-1212037Z



Project / Type _____

Notes _____

Count / Date _____

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1


MF	LMF × RSMF × LLMF × LSF	RSMF ^a	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF ^a	Luminaire Maintenance Factor	LSF	Lamp Survival Factor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.


Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	21
B13	27
B16	34
B20	42
C10	35
C13	45
C16	56
C20	70

Colour rendering



CRI/R_a ≥ 92 R_e ≥ 89 (3000 K)



MINO 40 mid lumen

suspended

042-1212037Z




Project / Type

Notes

Count / Date

TM30 colour vector graphic



The black line represents the black body reference. The red line indicates the results of the test light source. The deviation from the test light source to the reference is shown and is marked by arrows. The shorter the arrows, the higher the color rendering.