

FRAME 60 high lumen

trim system

007-93M3117 006-16092H 035-0093G



Project / Type _____

Notes _____

Count / Date _____



General

Ceiling , Recessed _____

grey , RAL 9006 ¹ _____

IP20 _____

1930 lm _____

2210 lm/m _____

LED

4000 K _____

CRI ≥ 90 _____

L90 / 50000 h _____

initial MacAdam ≤ 3 SDCM _____

R_g: 99 , R_r: 92 , R_{t(1-15)}: 90 _____

MR 0.81 _____

MDER 0.74 _____

Optical

High Performance Opal _____

opal (lambertsch) _____

PstLM ≤ 1.0 ² _____

SVM ≤ 0.4 ² _____

Electrical

non DIM _____

220-240 V _____

system 17.5 W _____

system 110 lm/W³ _____

PC1 _____

20 W/m _____

Physical

trim _____

length 872 mm _____

width 77 mm _____

height 78 mm _____

2.13 kg _____

Cutout

length 888 mm _____


width 66 mm _____

min. ceiling thickness 8 mm _____

max. ceiling thickness 25 mm _____

recessed depth 108 mm _____

Light distribution



Product drawing



¹ RAL code ² Value of containing product at full load (undimmed)
³ incl. consideration of optical losses, internal control unit losses
& operating device efficiency

Installation instructions



Lighting calculator

