


MITA circle 200 reflector

trim

074-8123637R



Project / Type _____
Notes _____
Count / Date _____



General

Ceiling | Recessed
white | RAL 9016 ¹
Reflector chrome
IP20
1870 lm

LED

4000 K
CRI \geq 80
L90 / 50000 h
initial MacAdam \leq 3 SDCM
MR 0.72 | MDER 0.65

Optical

Reflector | symmetric
UGR \leq 19 | $\geq 65^\circ$ < 1500 cd/m²
PstLM \leq 1.0 ² | SVM \leq 0.4 ²

Electrical

DALI-2
PC2 | 220-240 V
system 13.5 W
system 139 lm/W ³

Physical

diameter 210 mm | height 36 mm
0.83 kg


Cutout

diameter 200 mm
min. ceiling thickness 2 mm | max. ceiling
thickness 25 mm
recessed depth 62 mm


¹ RAL code ² Value of containing product at full load (undimmed)
³ incl. consideration of optical losses, internal control unit losses
& operating device efficiency

Ring-shaped light fitting in die-cast aluminium; extremely slim design; recessed light with wrap around edge; suitable for ceiling thickness of 2-25 mm; surface white powder coated; light colour 4000 K; binning initial MacAdam \leq 3 SDCM; CRI \geq 80; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; high gloss reflector with faceted design; Reflector chrome; UGR \leq 19; VDU compatible workplace luminaire according to DIN EN 12464-1; luminance above $65^\circ \leq 1500$ cd/m²; degree of protection IP20; PC2; 220-240 V; internal wiring in light halogen free; incl. DALI-2 converter; converter wired secondary side; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

Light distribution



Product drawing



Installation instructions



Lighting calculator



MITA circle 200 reflector

trim

074-8123637R



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1

MF	LMF × RSMF × LLMF × LSF	RSMF ^a	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF ^a	Luminaire Maintenance Factor	LSF	Lamp Survival Factor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	18
B16	30
C10	23
C16	36