

# MITA circle 450 reflector

## direct / indirect power

suspended

074-7651037R



Project / Type

Notes

Count / Date



### General

Ceiling , Suspended

white , RAL 9016 <sup>1</sup>

Reflector chrome

IP20

indirect 3320 lm

direct 3590 lm

total 6910 lm

### LED

3000 K

CRI  $\geq$  90

L90 / 50000 h

initial MacAdam  $\leq$  3 SDCM

R<sub>g</sub>: 99 , R<sub>r</sub>: 91 , R<sub>t(1-15)</sub>: 89

MR 0.61

MDER 0.55

### Optical

Reflector

symmetric

UGR  $\leq$  16 ,  $\geq 65^\circ$  <1500 cd/m<sup>2</sup>

PstLM  $\leq$  1.0 <sup>2</sup>

SVM  $\leq$  0.4 <sup>2</sup>

### Electrical

DALI-2

220-240 V

system 60 W

system 115 lm/W<sup>3</sup>

PC1

1 DALI Addr.

### Physical


diameter 426 mm

height 38 mm


<sup>1</sup> RAL code <sup>2</sup> Value of containing product at full load (undimmed)

<sup>3</sup> incl. consideration of optical losses, internal control unit losses & operating device efficiency

### Light distribution



### Product drawing



# MITA circle 450 reflector

## direct / indirect power

suspended

074-7651037R



Project / Type

Notes

Count / Date

### Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1

MF LMF × RSMF × LLMF × LSF  
MF Maintenance Factor  
LMF<sup>a</sup> Luminaire Maintenance Factor

RSMF<sup>a</sup> Room Surface Maintenance Factor  
LLMF Lamp Lumens Maintenance Factor  
LSF Lamp Survival Factor

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

### Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	10
B13	13
B16	16
B20	21
C10	16
C13	21
C16	26
C20	35

### Optical accessories

#### BLIND COVER circle 450 ceiling

COLOUR	Ø (MM)	ARTICLE NUMBER(S)
traffic white	339	074-8911627
jet black	339	074-8911628

