

MITA circle 160

ceiling

074-7616538R



| | |
|----------------|--|
| Project / Type | |
| Notes | |
| Count / Date | |



General

| |
|-----------------------------------|
| Ceiling , Surface |
| jet black , RAL 9005 ¹ |
| Reflector chrome |
| IP20 |
| 1050 lm |

LED

| |
|--------------------------|
| 3000 K |
| CRI ≥ 80 |
| L90 / 50000 h |
| initial MacAdam ≤ 3 SDCM |
| MR 0.56 |
| MDER 0.51 |

Optical

| |
|---|
| Reflector |
| symmetric |
| UGR ≤ 19 , ≥65° <1500 cd/m ² |
| PstLM ≤ 1.0 ² |
| SVM ≤ 0.4 ² |

Electrical


| |
|------------------------------|
| DALI-2 |
| 220-240 V |
| system 7.8 W |
| system 135 lm/W ³ |
| PC1 |
| 1 DALI Addr. |

Physical

| |
|-----------------|
| diameter 165 mm |
| height 76 mm |

¹ RAL code ² Value of containing product at full load (undimmed)
³ incl. consideration of optical losses, internal control unit losses
& operating device efficiency

Light distribution



Product drawing



Installation instructions



Lighting calculator



MITA circle 160

ceiling

074-7616538R



Project / Type

Notes

Count / Date

Maintenance Factors

| Operating Time [h] | 10 000 | 20 000 | 30 000 | 40 000 | 50 000 |
|--------------------|------------------------------|--------|-------------------|---------------------------------|--------|
| LLMF | 0.98 | 0.96 | 0.94 | 0.92 | 0.9 |
| LSF | 1 | 1 | 1 | 1 | 1 |
| MF | LMF × RSMF × LLMF × LSF | | RSMF ^a | Room Surface Maintenance Factor | |
| MF | Maintenance Factor | | LLMF | Lamp Lumens Maintenance Factor | |
| LMF ^a | Luminaire Maintenance Factor | | LSF | Lamp Survival Factor | |

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

| Automatic Circuit Breaker Type | Number of Fixtures |
|--------------------------------|--------------------|
| B10 | 37 |
| B16 | 60 |
| C10 | 37 |
| C16 | 60 |

