


SETA direct / indirect TW

power

suspended
074-52D6047B



Project / Type _____
Notes _____
Count / Date _____



General

Ceiling , Suspended _____
white , RAL 9010 ¹ _____
Reflector dark chrome _____
IP20 _____
indirect 3050 lm _____
direct 2120 lm _____
total 5170 lm _____

LED

3000 K _____
CRI ≥ 90 _____
L90 / 50000 h _____
initial MacAdam ≤ 3 SDCM _____
R_g: 99 , R_r: 91 , R₍₁₋₁₅₎: 89 _____
MR 0.61 _____
MDER 0.55 _____

Optical

Reflector _____
symmetric _____
UGR ≤ 10 , ≥65° <1500 cd/m² _____
P_{st}LM ≤ 1.0 ² _____
SVM ≤ 0.4 ² _____

Electrical


DALI-2 D/I separately controllable _____
220-240 V _____
system 53 W _____
system 98 lm/W³ _____
PC1 _____
1 DALI Addr. _____

Physical


length 1863 mm _____
width 60 mm _____
height 60 mm _____

Luminaire housing made of extruded aluminium profile; extremely slim design (only Ø 61 mm); light tight final end caps made of aluminium; no visible screws; surface white powder coated; suspended luminaire with 1500mm cable suspension; with integrated toolless suspension height adjustment on the luminaire; spring clip attachment to the luminaire; freely positionable; incl. feed (white); extruded profile for improved thermal management; high gloss reflector with faceted design; Reflector dark chrome; direct/indirect illumination characteristic; light colour direct light component: 3000 K; light colour indirect light component: tunable white diodes (2700-6500 K); binning initial MacAdam ≤ 3 SDCM; CRI ≥ 90; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; UGR ≤ 10; VDU compatible workplace luminaire according to DIN EN 12464-1; luminance above 65° ≤ 1500 cd/m²; indirect light component with integrated PC boards and high quality lens system for maximum, homogeneous ceiling illumination, separately controllable; degree of protection IP20; PC1; 220-240 V; internal wiring in light halogen free; incl. DALI-2 converter; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

Light distribution



Product drawing



¹ RAL code ² Value of containing product at full load (undimmed)
³ incl. consideration of optical losses, internal control unit losses & operating device efficiency

Installation instructions



Lighting calculator





Project / Type _____

Notes _____

Count / Date _____

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1

MF LMF × RSMF × LLMF × LSF RSMF^a Room Surface Maintenance Factor
 MF Maintenance Factor LLMF Lamp Lumens Maintenance Factor
 LMF^a Luminaire Maintenance Factor LSF Lamp Survival Factor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	9
B13	12
B16	15
B20	19
C10	15
C13	20
C16	25
C20	32