

SOUNDCATCHER sharp

octo 1000 light acoustic

suspended

091-3180638B 091-311320D



Project / Type

Notes

Count / Date



General

jet black | RAL 9005 ¹

marble grey

PET felt (made of at least 50% post-consumer recycled material)

IP20

1580 lm

LED

4000 K

CRI \geq 80

L90 / 50000 h

initial MacAdam \leq 3 SDCM

MR 0.72 | MDER 0.65

Optical

Reflector dark chrome | symmetric

UGR \leq 19 | $\geq 65^\circ$ <1500 cd/m²

PstLM \leq 1.0 ² | SVM \leq 0.4 ²

Electrical

DALI-2 | 1 DALI Addr.

PC1 | 220-240 V

system 13.7 W

system 115 lm/W ³

Physical


rod 977 mm

diameter 240 mm | height 45 mm




Acoustic element made of high quality, self-supporting, at least 50% recycled PET felt with sound absorbing properties; in different moldings; constructed of two layers; choice of square, round or octagonal design; suitable for single or group installation; high quality visual and tactile surface; acoustically effective cavities; large sound absorbing surface; absorption of direct sound and sound reflected from the ceiling; this creates high acoustic performance; pendant fitting with MITA circle 240 acoustic suspended (LUMINAIRE or BLIND SUSPENSION); LUMINAIRE: ring shaped luminaire housing in die-cast aluminium; extremely slim design; surface powder coated; suspended; with height adjustable rod suspension (chrome), feed in rod; electronic operating unit installed in the canopy; high gloss reflector with faceted design; energy-efficient LEDs with very good colour rendering; optionally with sensor

Light distribution



Product drawing



¹ RAL code ² Value of containing product at full load (undimmed)

³ incl. consideration of optical losses, internal control unit losses & operating device efficiency

SOUNDCATCHER sharp
octo 1000 light acoustic
suspended
091-3180638B 091-311320D



Project / Type _____

Notes _____

Count / Date _____

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF ^a	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF ^a	Luminaire Maintenance Factor		LSF	Lamp Survival Factor	

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	72
B16	115
C10	106
C16	170

Equivalent sound absorption area (A_{eq})

125 HZ	250 HZ	500 HZ	1000 HZ	2000 HZ	4000 HZ
0.4	0.8	1	1.4	1.7	1.9

Components

SOUNDCATCHER sharp octo

COLOUR	L-W-H (MM)	ARTICLE NUMBER(S)
marble grey	1000-1000-150	091-311320D

Mounting accessories

SYSTEM CONNECTOR

TYPE	COLOUR	ARTICLE NUMBER(S)
set of two connectors	traffic white	091-3191007
set of two connectors	jet black	091-3191008

