

TASK square

suspended


EN Square housing made of aluminium with rounded edges; ultra low-profile design (only 15 mm); surface powder coated; pendant fitting with cable suspension (4 cables); with integrated toolless suspension height adjustment; incl. feeder cable; direct light distribution by LGP body (Light Guiding Prism); side coupled light directed downwards by laser engraving; light control via highly reflective reflector material; optional: indirect light component with special PCBs for increased luminous flux and maximum ceiling illumination; completely homogeneous illumination; energy-efficient LEDs with very good colour rendering; canopy for through wiring; sound absorbing accessories available

ES Cuerpo de luminaria cuadrado de aluminio con cantos redondeados; perfil extra plano (sólo 15 mm); superficie con recubrimiento de pintura en polvo; suspendido con cable (4 cables); regulación de la altura sin necesitar herramientas; incl. cable de alimentación; distribución de luz directa a través de cuerpo LGP (Light Guiding Prism); la luz acoplada lateralmente se orienta hacia abajo por medio de un grabado por láser; orientación luz por medio de un elemento altamente reflectante; opcional: proporción indirecta con pletinas propias para un flujo luminoso aumentado y una iluminación máxima del techo; iluminación homogénea; LEDs de alta eficiencia que proporcionan una alta reproducción cromática; baldaquino para cableado pasante; disponible accesorio para la absorción del ruido

Quickinfo

3000 K, 4000 K
 CRI ≥ 90 / 3 SDCM
 UGR ≤ 19
 hasta 6,020 lm / \uparrow 1,620 lm
 hasta 137 lm/W
 L90 / 50000 h
 DALI-2
 Microprismatic
 IP20

Types



Color



Distribución luminosa



DiiA® standards
 251, 252, 253




DIN EN 12464-1
 UGR ≤ 19




flat design (15 mm)




acoustic
 elements



CRI ≥ 98
XPECTRUM
 (optional)




TASK 450 square suspended



MICROPRISMATIC | DIRECT DALI-2, CRI ≥ 90

SYSTEM	COLOUR TEMP.	LUM. FLUX	SYSTEM	ORDER CODE
15.0 W	3000 K	1880 lm	125 lm/W	0 5 9 - 2 2 1 1 0 3 <input checked="" type="checkbox"/> K
	4000 K	2000 lm	133 lm/W	0 5 9 - 2 2 1 1 1 3 <input checked="" type="checkbox"/> K




MICROPRISMATIC | DIRECT / INDIRECT POWER DALI-2, CRI ≥ 90

SYSTEM	COLOUR TEMP.	LUM. FLUX	SYSTEM	ORDER CODE
35.0 W	3000 K	↓2910/↑1470 lm	125 lm/W	0 5 9 - 2 2 3 1 0 3 <input checked="" type="checkbox"/> K
	4000 K	↓3100/↑1570 lm	133 lm/W	0 5 9 - 2 2 3 1 1 3 <input checked="" type="checkbox"/> K




TASK 600 square suspended



MICROPRISMATIC | DIRECT DALI-2, CRI ≥ 90



SYSTEM	COLOUR TEMP.	LUM. FLUX	SYSTEM	ORDER CODE
27.3 W	3000 K	3510 lm	129 lm/W	0 5 9 - 2 2 1 2 0 3 <input checked="" type="checkbox"/> K
	4000 K	3730 lm	137 lm/W	0 5 9 - 2 2 1 2 1 3 <input checked="" type="checkbox"/> K



MICROPRISMATIC | DIRECT / INDIRECT POWER DALI-2, CRI ≥ 90

SYSTEM	COLOUR TEMP.	LUM. FLUX	SYSTEM	ORDER CODE
57.0 W	3000 K	↓5660/↑1530 lm	126 lm/W	0 5 9 - 2 2 3 2 0 3 <input checked="" type="checkbox"/> K
	4000 K	↓6020/↑1620 lm	134 lm/W	0 5 9 - 2 2 3 2 1 3 <input checked="" type="checkbox"/> K

Planning Information



TASK 600 square suspended
57W, 4000K, direct/indirect power

ROOM VALUES

Room dimensions	5.4 × 4 × 2.8 m
Reflection factor	0.7 0.5 0.2
Maintenance factor	0.8
Suspension height	2.25 m

CALCULATION SURFACE

Surface dimensions	1.6 × 0.8 m
Surface height	0.75 m
Average illuminance (E_m)	> 500 lx
Uniformity (U_0)	> 0.6

GLARE EVALUATION

Table Classification $X=4H$ $Y=8H$ $S=0.25H$	
UGR transversal	≤ 19
UGR axial	≤ 19
UGR axial	≤ 19

Order options

COLOUR	
pure white RAL 9010	7
jet black RAL 9005	8
special colours	X