

VARO 110 S

180-6531037F



Projet / Type _____

Notes _____

Quantité / Date _____



Général

Plafond , Rail _____

inclinaison max 90° _____

rotation 355° _____

blanc , RAL9016 ¹ _____

IP20 _____

4480 lm _____

LED

3000 K _____

CRI ≥ 90 _____

L85 / 50000 h _____

MacAdam initial ≤ 3 SDCM _____

R_g: 99 , R_f: 92 , R₍₁₋₁₅₎: 93 _____

MR 0.61 _____

MDER 0.55 _____

Optique

flood _____

angle de faisceau 40° _____

Electrique

DALI-2 _____

36 W _____

CP2 220-240V _____

124 lm/W _____


Physique

diamètre 110 mm _____

hauteur 110 mm _____

¹ Code RAL


Répartition de la lumière



flood 40°

h (m)	E0° (lx)	ø (m)
1	8410	0.73
2	2100	1.46
3	930	2.18
4	530	2.91
5	340	3.64

Dessin de fabrication



Notice de montage



Calculateur d'éclairage

