

VARO 110 S

180-6530138M



Projet / Type _____

Notes _____

Quantité / Date _____



Général

Plafond , Rail _____

inclinaison max 90° _____

rotation 355° _____

noir , RAL9005 ¹ _____

IP20 _____

3200 lm _____

LED

4000 K _____

CRI ≥ 90 _____

L85 / 50000 h _____

MacAdam initial ≤ 3 SDCM _____

R_g: 100 , R_f: 92 , R_{f(1-5)}: 91 _____

MR 0.78 _____

MDER 0.71 _____

Optique

medium _____

angle de faisceau 25° _____

Electrique

DALI-2 _____

23.4 W _____

CP2 220-240V _____

137 lm/W _____


Physique

diamètre 110 mm _____

hauteur 110 mm _____

¹ Code RAL


Répartition de la lumière



medium 25°

h (m)	E0° (lx)	ø (m)
1	11100	0.45
2	2800	0.90
3	1200	1.35
4	700	1.81
5	400	2.26

Dessin de fabrication



Notice de montage



Calculateur d'éclairage

