

VARO 110 S

180-6531137M



Projet / Type _____

Notes _____

Quantité / Date _____



Général

Plafond , Rail _____

inclinaison max 90° _____

rotation 355° _____

blanc , RAL9016 ¹ _____

IP20 _____

4480 lm _____

LED

4000 K _____

CRI ≥ 90 _____

L85 / 50000 h _____

MacAdam initial ≤ 3 SDCM _____

R_g: 100 , R_f: 92 , R_{f(1-5)}: 91 _____

MR 0.78 _____

MDER 0.71 _____

Optique

medium _____

angle de faisceau 25° _____

Electrique

DALI-2 _____

36 W _____

CP2 220-240V _____

124 lm/W _____


Physique

diamètre 110 mm _____

hauteur 110 mm _____

¹ Code RAL


Répartition de la lumière



medium 25°

h (m)	E0° (lx)	ø (m)
1	15500	0.45
2	3900	0.90
3	1700	1.35
4	1000	1.81
5	600	2.26

Dessin de fabrication



Notice de montage



Calculateur d'éclairage

